

APPENDIX C

THIRD QUARTER 2012 SUMMARY TABLES, DISCHARGE
MONITORING DATA

**THIRD QUARTER 2012
REPORTING SUMMARY NOTES
THE BOEING COMPANY
SANTA SUSANA FIELD LABORATORY
NPDES PERMIT CA0001309**

**THIRD QUARTER 2012
REPORTING SUMMARY NOTES
THE BOEING COMPANY**

**THIRD QUARTER 2012
REPORTING SUMMARY NOTES
THE BOEING COMPANY
SANTA SUSANA FIELD LABORATORY
NPDES PERMIT CA0001309**

NM	not measured or determined
NTU	nephelometric turbidity unit
pCi/L	picocuries per liter
pg/L	picograms per liter
Q	matrix spike recovery outside of control limits
R	as a validation qualifier, results are rejected; the presence or absence of analyte cannot be verified
R	(reason code in parentheses) %R for calibration not within control limits
RL	laboratory reporting limit
RL-1	reporting limit raised due to sample matrix effects
%RSD	percent relative standard deviation
S	surrogate recovery was outside control limits
TEQ	toxic equivalent
T	presumed contamination, as indicated by a detect in the trip blank
TU _c	toxicity units (chronic)
U	result not detected
µg/L	micrograms per liter
UJ	result not detected at the estimated reporting limit
umhos/cm	micromhos per centimeter
WHO TEF	World Health Organization toxic equivalency factor
^	analysis not completed due to hold time exceedence or insufficient sample volume
#	Per ORDER NO. R4-2010-0090 page 23 Footnote 1. The effluent limitations for total suspended solids and settleable solids are not applicable for discharges during wet weather. During wet weather flow, a discharge event is greater than 0.1 inches of rainfall in a 24-hour period. No more than one sample per week need be obtained during extended periods of rainfall or the discharge of collected stormwater. A storm event must be preceded by at least 72 hours of dry weather.
(4.0)3.1/-	Represents (Dry Weather Limit) Wet Weather Limit / Monthly Average Limit.

OUTFALL 019 (Treatment System)

**THIRD QUARTER 2012 REPORTING SUMMARY
THE BOEING COMPANY
SANTA SUSANA FIELD LABORATORY
NPDES PERMIT CA0001309**

July 1 through September 30, 2012

ANALYTE	UNITS	Permit Limit Daily Max/Monthly Avg	07/02/2012-07/03/2012		
			SAMPLE TYPE	RESULT	VALIDATION QUALIFIER
Ammonia as Nitrogen (N)	mg/L	10.1/1.96	Comp	0.280	J (DNQ)
Biochemical Oxygen Demand (BOD 5 day)	mg/L	30/20	Comp	4.1	--
Chloride	mg/L	150/-	Comp	34	*
Dissolved Oxygen	mg/L	-/-	Grab	7.52	*
Specific Conductivity (Lab)	umhos/cm	-/-	Grab	680	*
Surfactants (MBAS)	mg/L	0.5/-	Comp	ND < 0.050	*
Fluoride	mg/L	1.6/-	ANR	ANR	ANR
Nitrate + Nitrite as Nitrogen (N)	mg/L	8/-	Comp	ND < 0.11	*
Nitrate as Nitrogen (N)	mg/L	8/-	Comp	ND < 0.080	*
Nitrite as Nitrogen (N)	mg/L	-/-	Comp	ND < 0.11	*
Oil & Grease	mg/L	15/10	Grab	ND < 1.3	*
Perchlorate	ug/L	6.0/-	Comp	ND < 0.95	U
pH (Field)	pH units	6.5-8.5/-	Grab	7.0	*
Total Settleable Solids	ml/L	0.3/0.1	Grab	ND < 0.10	*
Sulfate	mg/L	300/-	Comp	150	*
Temperature	deg. F	86/-	Grab	64	*
Total Cyanide	ug/L	8.5/4.3	Comp	ND < 3.0	*
Total Dissolved Solids	mg/L	950/-	Comp	520	*
Hardness	mg/L	-/-	Comp	310	--
Hardness, dissolved	mg/L	-/-	Comp	300	--
Total Organic Carbon	mg/L	-/-	Comp	0.95	J (DNQ)
Total Residual Chlorine (Field)	mg/L	0.1/-	ANR	ANR	ANR
Total Suspended Solids	mg/L	45/15	Comp	ND < 10	*
Turbidity	NTU	-/-	Comp	0.060	J (DNQ)
Volume Discharged	MGD	160/-	Meas	0.0287568	*
METALS					
Antimony	ug/L	6.0/-	ANR	ANR	ANR
Arsenic	ug/L	10/-	ANR	ANR	ANR
Barium	mg/L	1.0/-	ANR	ANR	ANR
Beryllium	ug/L	4.0/-	ANR	ANR	ANR
Boron	mg/L	-/-	ANR	ANR	ANR
Cadmium	ug/L	(4.0)3.1/2.0	Comp	ND < 0.10	*
Cadmium, dissolved	ug/L	-/-	Comp	ND < 0.10	*
Chromium	ug/L	16/8	ANR	ANR	ANR
Chromium VI	ug/L	16/8	ANR	ANR	ANR
Cobalt	ug/L	-/-	ANR	ANR	ANR
Copper	ug/L	14/7.1	Comp	ND < 0.50	*
Copper, dissolved	ug/L	-/-	Comp	0.51	J,DX* (DNQ)
Iron	mg/L	0.3/-	ANR	ANR	ANR
Lead	ug/L	5.2/2.6	Comp	ND < 0.20	*
Lead, dissolved	ug/L	-/-	Comp	ND < 0.20	*
Manganese	ug/L	50/-	ANR	ANR	ANR
Mercury	ug/L	0.10/0.05	Comp	ND < 0.10	U
Mercury, dissolved	ug/L	-/-	Comp	ND < 0.10	U
Nickel	ug/L	96/35	ANR	ANR	ANR
Selenium	ug/L	(5.0)8.2/4.1	Comp	ND < 0.50	*

OUTFALL 019 (Treatment System)

**THIRD QUARTER 2012 REPORTING SUMMARY
THE BOEING COMPANY
SANTA SUSANA FIELD LABORATORY
NPDES PERMIT CA0001309**

July 1 through September 30, 2012

ANALYTE	UNITS	Permit Limit Daily Max/Monthly Avg	07/02/2012-07/03/2012		
			SAMPLE TYPE	RESULT	VALIDATION QUALIFIER
Selenium, dissolved	ug/L	-/-	Comp	ND < 0.50	*
Silver	ug/L	4.1/2.0	ANR	ANR	ANR
Thallium	ug/L	2.0/-	ANR	ANR	ANR
Vanadium	ug/L	-/-	ANR	ANR	ANR
Zinc	ug/L	119/54	Comp	ND < 6.0	U
Zinc, Dissolved	ug/L	-/-	Comp	ND < 6.0	U
ORGANICS					
Benzene	ug/L	-/-	Grab	ND < 0.28	*
Carbon Tetrachloride	ug/L	-/-	Grab	ND < 0.28	*
Chloroform	ug/L	-/-	Grab	ND < 0.33	*
1,1-Dichloroethane	ug/L	-/-	Grab	ND < 0.40	*
1,2-Dichloroethane	ug/L	-/-	Grab	ND < 0.28	*
1,1-Dichloroethene	ug/L	6.0/3.2	Grab	ND < 0.42	*
1,4-Dioxane	ug/L	-/-	ANR	ANR	ANR
Ethylbenzene	ug/L	-/-	Grab	ND < 0.25	*
Tetrachloroethene	ug/L	-/-	Grab	ND < 0.32	*
Toluene	ug/L	-/-	Grab	ND < 0.36	*
Xylenes (Total)	ug/L	-/-	Grab	ND < 0.90	*
1,1,1-Trichloroethane	ug/L	-/-	Grab	ND < 0.30	*
1,1,2-Trichloroethane	ug/L	-/-	Grab	ND < 0.30	*
Trichloroethene	ug/L	5.0/-	Grab	ND < 0.26	*
Trichlorofluoromethane	ug/L	-/-	Grab	ND < 0.34	*
Trichlorotrifluoroethane (Freon 113)	ug/L	-/-	Grab	ND < 0.50	*
Vinyl Chloride	ug/L	-/-	Grab	ND < 0.40	*
TPH					
GRO (C4 - C12)	mg/L	-/-	ANR	ANR	ANR
ADDITIONAL ANALYTES					
1,2-Dichloro-1,1,2-trifluoroethane	ug/L	-/-	ANR	ANR	ANR
1,1,2,2-Tetrachloroethane	ug/L	-/-	ANR	ANR	ANR
1,2,4-Trichlorobenzene	ug/L	-/-	ANR	ANR	ANR
1,2-Dichlorobenzene	ug/L	-/-	ANR	ANR	ANR
1,2-Dichloropropane	ug/L	-/-	ANR	ANR	ANR
1,2-Diphenylhydrazine/Azobenzene	ug/L	-/-	ANR	ANR	ANR
1,3-Dichlorobenzene	ug/L	-/-	ANR	ANR	ANR
1,4-Dichlorobenzene	ug/L	-/-	ANR	ANR	ANR
2,4,6-Trichlorophenol	ug/L	13/6.5	Comp	ND < 0.0943	*
2,4-Dichlorophenol	ug/L	-/-	ANR	ANR	ANR
2,4-Dimethylphenol	ug/L	-/-	ANR	ANR	ANR
2,4-Dinitrophenol	ug/L	-/-	ANR	ANR	ANR
2,4-Dinitrotoluene	ug/L	18/9.1	Comp	ND < 0.189	*
2,6-Dinitrotoluene	ug/L	-/-	ANR	ANR	ANR
2-Chloroethylvinylether	ug/L	-/-	ANR	ANR	ANR
2-Chloronaphthalene	ug/L	-/-	ANR	ANR	ANR
2-Chlorophenol	ug/L	-/-	ANR	ANR	ANR
2-Methyl-4,6-dinitrophenol	ug/L	-/-	ANR	ANR	ANR
2-Nitrophenol	ug/L	-/-	ANR	ANR	ANR
3,3'-Dichlorobenzidine	ug/L	-/-	ANR	ANR	ANR

OUTFALL 019 (Treatment System)

**THIRD QUARTER 2012 REPORTING SUMMARY
THE BOEING COMPANY
SANTA SUSANA FIELD LABORATORY
NPDES PERMIT CA0001309**

July 1 through September 30, 2012

ANALYTE	UNITS	Permit Limit Daily Max/Monthly Avg	07/02/2012-07/03/2012		
			SAMPLE TYPE	RESULT	VALIDATION QUALIFIER
4,4'-DDD	ug/L	-/-	ANR	ANR	ANR
4,4'-DDE	ug/L	-/-	ANR	ANR	ANR
4,4'-DDT	ug/L	-/-	ANR	ANR	ANR
4-Bromophenylphenylether	ug/L	-/-	ANR	ANR	ANR
4-Chloro-3-methylphenol	ug/L	-/-	ANR	ANR	ANR
4-Chlorophenylphenylether	ug/L	-/-	ANR	ANR	ANR
4-Nitrophenol	ug/L	-/-	ANR	ANR	ANR
Acenaphthene	ug/L	-/-	ANR	ANR	ANR
Acrolein	ug/L	-/-	ANR	ANR	ANR
Acrylonitrile	ug/L	-/-	ANR	ANR	ANR
Acute Toxicity	% SURVIVAL	70-100/-	Comp	100	*
Aldrin	ug/L	-/-	ANR	ANR	ANR
alpha-BHC	ug/L	0.03/0.01	Comp	ND < 0.0024	*
Anthracene	ug/L	-/-	ANR	ANR	ANR
Aroclor-1016	ug/L	-/-	ANR	ANR	ANR
Aroclor-1221	ug/L	-/-	ANR	ANR	ANR
Aroclor-1232	ug/L	-/-	ANR	ANR	ANR
Aroclor-1242	ug/L	-/-	ANR	ANR	ANR
Aroclor-1248	ug/L	-/-	ANR	ANR	ANR
Aroclor-1254	ug/L	-/-	ANR	ANR	ANR
Aroclor-1260	ug/L	-/-	ANR	ANR	ANR
Benzidine	ug/L	-/-	ANR	ANR	ANR
Benzo(a)anthracene	ug/L	-/-	ANR	ANR	ANR
Benzo(a)pyrene	ug/L	-/-	ANR	ANR	ANR
Benzo(b)fluoranthene	ug/L	-/-	ANR	ANR	ANR
Benzo(g,h,i)perylene	ug/L	-/-	ANR	ANR	ANR
Benzo(k)fluoranthene	ug/L	-/-	ANR	ANR	ANR
beta-BHC	ug/L	-/-	ANR	ANR	ANR
bis (2-Chloroethyl) ether	ug/L	-/-	ANR	ANR	ANR
bis (2-ethylhexyl) Phthalate	ug/L	4.0/-	Comp	ND < 1.60	*
bis(2-Chloroethoxy) methane	ug/L	-/-	ANR	ANR	ANR
bis(2-Chloroisopropyl) ether	ug/L	-/-	ANR	ANR	ANR
Bromodichloromethane	ug/L	-/-	ANR	ANR	ANR
Bromoform	ug/L	-/-	ANR	ANR	ANR
Bromomethane	ug/L	-/-	ANR	ANR	ANR
Butylbenzylphthalate	ug/L	-/-	ANR	ANR	ANR
Chlordane	ug/L	-/-	ANR	ANR	ANR
Chlorobenzene	ug/L	-/-	ANR	ANR	ANR
Chloroethane	ug/L	-/-	ANR	ANR	ANR
Chloromethane	ug/L	-/-	ANR	ANR	ANR
Chronic Toxicity	TUC	1.0/-	ANR	ANR	ANR
Chrysene	ug/L	-/-	ANR	ANR	ANR
cis-1,2-Dichloroethene	ug/L	-/-	Grab	ND < 0.32	*
cis-1,3-Dichloropropene	ug/L	-/-	ANR	ANR	ANR
Cyclohexane	ug/L	-/-	ANR	ANR	ANR
delta-BHC	ug/L	-/-	ANR	ANR	ANR
Dibenzo(a,h)anthracene	ug/L	-/-	ANR	ANR	ANR

OUTFALL 019 (Treatment System)

**THIRD QUARTER 2012 REPORTING SUMMARY
THE BOEING COMPANY
SANTA SUSANA FIELD LABORATORY
NPDES PERMIT CA0001309**

July 1 through September 30, 2012

ANALYTE	UNITS	Permit Limit Daily Max/Monthly Avg	07/02/2012-07/03/2012		
			SAMPLE TYPE	RESULT	VALIDATION QUALIFIER
Dibromochloromethane	ug/L	-/-	ANR	ANR	ANR
Dieldrin	ug/L	-/-	ANR	ANR	ANR
Diethylphthalate	ug/L	-/-	ANR	ANR	ANR
Dimethylphthalate	ug/L	-/-	ANR	ANR	ANR
Di-n-butylphthalate	ug/L	-/-	ANR	ANR	ANR
Di-n-octylphthalate	ug/L	-/-	ANR	ANR	ANR
Endosulfan I	ug/L	-/-	ANR	ANR	ANR
Endosulfan II	ug/L	-/-	ANR	ANR	ANR
Endosulfan sulfate	ug/L	-/-	ANR	ANR	ANR
Endrin	ug/L	-/-	ANR	ANR	ANR
Endrin aldehyde	ug/L	-/-	ANR	ANR	ANR
Fluoranthene	ug/L	-/-	ANR	ANR	ANR
Fluorene	ug/L	-/-	ANR	ANR	ANR
Heptachlor	ug/L	-/-	ANR	ANR	ANR
Heptachlor epoxide	ug/L	-/-	ANR	ANR	ANR
Hexachlorobenzene	ug/L	-/-	ANR	ANR	ANR
Hexachlorobutadiene	ug/L	-/-	ANR	ANR	ANR
Hexachlorocyclopentadiene	ug/L	-/-	ANR	ANR	ANR
Hexachloroethane	ug/L	-/-	ANR	ANR	ANR
Indeno(1,2,3-cd)pyrene	ug/L	-/-	ANR	ANR	ANR
Isophorone	ug/L	-/-	ANR	ANR	ANR
Lindane (gamma-BHC)	ug/L	-/-	ANR	ANR	ANR
Methylene Chloride	ug/L	-/-	ANR	ANR	ANR
Monomethyl Hydrazine	ug/L	-/-	ANR	ANR	ANR
Naphthalene	ug/L	-/-	ANR	ANR	ANR
Nitrobenzene	ug/L	-/-	ANR	ANR	ANR
n-Nitrosodimethylamine	ug/L	16/8.1	Comp	ND < 0.0943	BA*
n-Nitroso-di-n-propylamine	ug/L	-/-	ANR	ANR	ANR
n-Nitrosodiphenylamine	ug/L	-/-	ANR	ANR	ANR
Pentachlorophenol	ug/L	16.5/8.2	Comp	ND < 0.377	*
Phenanthrene	ug/L	-/-	ANR	ANR	ANR
Phenol	ug/L	-/-	ANR	ANR	ANR
Pyrene	ug/L	-/-	ANR	ANR	ANR
Toxaphene	ug/L	-/-	ANR	ANR	ANR
trans-1,2-Dichloroethene	ug/L	-/-	ANR	ANR	ANR
trans-1,3-Dichloropropene	ug/L	-/-	ANR	ANR	ANR

OUTFALL 019 (Treatment System)

THIRD QUARTER 2012 REPORTING SUMMARY
 THE BOEING COMPANY
 SANTA SUSANA FIELD LABORATORY
 NPDES PERMIT CA0001309

July 1 through September 30, 2012

ANALYTE	UNITS	Permit Limit Daily Max/Monthly Avg
Selenium, dissolved	ug/L	-/-
Silver	ug/L	4.1/2.0
Thallium	ug/L	2.0/-
Vanadium	ug/L	-/-
Zinc	ug/L	119/54
Zinc, Dissolved	ug/L	-/-
ORGANICS		
Benzene	ug/L	-/-
Carbon Tetrachloride	ug/L	-/-
Chloroform	ug/L	-/-
1,1-Dichloroethane	ug/L	-/-
1,2-Dichloroethane	ug/L	-/-
1,1-Dichloroethene	ug/L	6.0/3.2
1,4-Dioxane	ug/L	-/-
Ethylbenzene	ug/L	-/-
Tetrachloroethene	ug/L	-/-
Toluene	ug/L	-/-
Xylenes (Total)	ug/L	-/-
1,1,1-Trichloroethane	ug/L	-/-
1,1,2-Trichloroethane	ug/L	-/-
Trichloroethene	ug/L	5.0/-
Trichlorofluoromethane	ug/L	-/-

OUTFALL 019 (Treatment System)

**THIRD QUARTER 2012 REPORTING SUMMARY
THE BOEING COMPANY
SANTA SUSANA FIELD LABORATORY
NPDES PERMIT CA0001309**

July 1 through September 30, 2012

ANALYTE	UNITS	Permit Limit Daily Max/Monthly Avg	08/01/2012-08/02/2012		
			SAMPLE TYPE	RESULT	VALIDATION QUALIFIER
4,4'-DDD	ug/L	-/-	ANR	ANR	ANR
4,4'-DDE	ug/L	-/-	ANR	ANR	ANR
4,4'-DDT	ug/L	-/-	ANR	ANR	ANR
4-Bromophenylphenylether	ug/L	-/-	ANR	ANR	ANR
4-Chloro-3-methylphenol	ug/L	-/-	ANR	ANR	ANR
4-Chlorophenylphenylether	ug/L	-/-	ANR	ANR	ANR
4-Nitrophenol	ug/L	-/-	ANR	ANR	ANR
Acenaphthene	ug/L	-/-	ANR	ANR	ANR
Acrolein	ug/L	-/-	ANR	ANR	ANR
Acrylonitrile	ug/L	-/-	ANR	ANR	ANR
Acute Toxicity	% SURVIVAL	70-100/-	ANR	ANR	ANR
Aldrin	ug/L	-/-	ANR	ANR	ANR
alpha-BHC	ug/L	0.03/0.01	Comp	ND < 0.0024	*
Anthracene	ug/L	-/-	ANR	ANR	ANR
Aroclor-1016	ug/L	-/-	ANR	ANR	ANR
Aroclor-1221	ug/L	-/-	ANR	ANR	ANR
Aroclor-1232	ug/L	-/-	ANR	ANR	ANR
Aroclor-1242	ug/L	-/-	ANR	ANR	ANR
Aroclor-1248	ug/L	-/-	ANR	ANR	ANR
Aroclor-1254	ug/L	-/-	ANR	ANR	ANR
Aroclor-1260	ug/L	-/-	ANR	ANR	ANR
Benzidine	ug/L	-/-	ANR	ANR	ANR
Benzo(a)anthracene	ug/L	-/-	ANR	ANR	ANR
Benzo(a)pyrene	ug/L	-/-	ANR	ANR	ANR
Benzo(b)fluoranthene	ug/L	-/-	ANR	ANR	ANR
Benzo(g,h,l)perylene	ug/L	-/-	ANR	ANR	ANR
Benzo(k)fluoranthene	ug/L	-/-	ANR	ANR	ANR
beta-BHC	ug/L	-/-	ANR	ANR	ANR
bis (2-Chloroethyl) ether	ug/L	-/-	ANR	ANR	ANR
bis (2-ethylhexyl) Phthalate	ug/L	4.0/-	Comp	ND < 1.60	*
bis(2-Chloroethoxy) methane	ug/L	-/-	ANR	ANR	ANR
bis(2-Chloroisopropyl) ether	ug/L	-/-	ANR	ANR	ANR
Bromodichloromethane	ug/L	-/-	ANR	ANR	ANR
Bromoform	ug/L	-/-	ANR	ANR	ANR
Bromomethane	ug/L	-/-	ANR	ANR	ANR
Butylbenzylphthalate	ug/L	-/-	ANR	ANR	ANR
Chlordane	ug/L	-/-	ANR	ANR	ANR
Chlorobenzene	ug/L	-/-	ANR	ANR	ANR
Chloroethane	ug/L	-/-	ANR	ANR	ANR
Chloromethane	ug/L	-/-	ANR	ANR	ANR
Chronic Toxicity	TUC	1.0/-	ANR	ANR	ANR
Chrysene	ug/L	-/-	ANR	ANR	ANR
cis-1,2-Dichloroethene	ug/L	-/-	Grab	ND < 0.32	*
cis-1,3-Dichloropropene	ug/L	-/-	ANR	ANR	ANR
Cyclohexane	ug/L	-/-	ANR	ANR	ANR
delta-BHC	ug/L	-/-	ANR	ANR	ANR
Dibenzo(a,h)anthracene	ug/L	-/-	ANR	ANR	ANR

OUTFALL 019 (Treatment System)

OUTFALL 019 (Treatment System)

**THIRD QUARTER 2012 REPORTING SUMMARY
THE BOEING COMPANY
SANTA SUSANA FIELD LABORATORY
NPDES PERMIT CA0001309**

July 1 through September 30, 2012

ANALYTE	UNITS	Permit Limit Daily Max/Monthly Ava
Ammonia as Nitrogen (N)	mg/L	10.1/1.96
Biochemical Oxygen Demand (BOD 5 day)	mg/L	30/20
Chloride	mg/L	150/-
Dissolved Oxygen	mg/L	-/-
Specific Conductivity (Lab)	umhos/cm	-/-
Surfactants (MBAS)	mg/L	0.5/-
Fluoride	mg/L	1.6/-
Nitrate + Nitrite as Nitrogen (N)	mg/L	8/-
Nitrate as Nitrogen (N)	mg/L	8/-
Nitrite as Nitrogen (N)	mg/L	-/-
Oil & Grease	mg/L	15/10
Perchlorate	ug/L	6.0/-
pH (Field)	pH units	6.5-8.5/-
Total Settleable Solids	ml/L	0.3/0.1
Sulfate	mg/L	300/-
Temperature	deg. F	86/-
Total Cyanide	ug/L	8.5/4.3
Total Dissolved Solids	mg/L	950/-
Hardness	mg/L	-/-
Hardness, dissolved	mg/L	-/-
Total Organic Carbon	mg/L	-/-

OUTFALL 019 (Treatment System)

**THIRD QUARTER 2012 REPORTING SUMMARY
THE BOEING COMPANY
SANTA SUSANA FIELD LABORATORY
NPDES PERMIT CA0001309**

July 1 through September 30, 2012

ANALYTE	UNITS	Permit Limit Daily Max/Monthly Avg	09/05/2012-09/06/2012		
			SAMPLE TYPE	RESULT	VALIDATION QUALIFIER
Selenium, dissolved	ug/L	-/-	Comp	ND < 0.50	*
Silver	ug/L	4.1/2.0	ANR	ANR	ANR
Thallium	ug/L	2.0/-	ANR	ANR	ANR
Vanadium	ug/L	-/-	ANR	ANR	ANR
Zinc	ug/L	119/54	Comp	ND < 6.0	*
Zinc, Dissolved	ug/L	-/-	Comp	ND < 6.0	*
ORGANICS					
Benzene	ug/L	-/-	Grab	ND < 0.28	*
Carbon Tetrachloride	ug/L	-/-	Grab	ND < 0.28	*
Chloroform	ug/L	-/-	Grab	ND < 0.33	*
1,1-Dichloroethane	ug/L	-/-	Grab	ND < 0.40	*
1,2-Dichloroethane	ug/L	-/-	Grab	ND < 0.28	*
1,1-Dichloroethene	ug/L	6.0/3.2	Grab	ND < 0.42	*
1,4-Dioxane	ug/L	-/-	ANR	ANR	ANR
Ethylbenzene	ug/L	-/-	Grab	ND < 0.25	*
Tetrachloroethene	ug/L	-/-	Grab	ND < 0.32	*
Toluene	ug/L	-/-	Grab	ND < 0.36	*
Xylenes (Total)	ug/L	-/-	Grab	ND < 0.90	*
1,1,1-Trichloroethane	ug/L	-/-	Grab	ND < 0.30	*
1,1,2-Trichloroethane	ug/L	-/-	Grab	ND < 0.30	*
Trichloroethene	ug/L	5.0/-	Grab	ND < 0.26	*
Trichlorofluoromethane	ug/L	-/-	Grab	ND < 0.34	*
Trichlorotrifluoroethane (Freon 113)	ug/L	-/-	Grab	ND < 0.50	*
Vinyl Chloride	ug/L	-/-	Grab	ND < 0.40	*
TPH					
GRO (C4 - C12)	mg/L	-/-	ANR	ANR	ANR
ADDITIONAL ANALYTES					
1,2-Dichloro-1,1,2-trifluoroethane	ug/L	-/-	ANR	ANR	ANR
1,1,2,2-Tetrachloroethane	ug/L	-/-	ANR	ANR	ANR
1,2,4-Trichlorobenzene	ug/L	-/-	ANR	ANR	ANR
1,2-Dichlorobenzene	ug/L	-/-	ANR	ANR	ANR
1,2-Dichloropropane	ug/L	-/-	ANR	ANR	ANR
1,2-Diphenylhydrazine/Azobenzene	ug/L	-/-	ANR	ANR	ANR
1,3-Dichlorobenzene	ug/L	-/-	ANR	ANR	ANR
1,4-Dichlorobenzene	ug/L	-/-	ANR	ANR	ANR
2,4,6-Trichlorophenol	ug/L	13/6.5	Comp	ND < 0.0943	*
2,4-Dichlorophenol	ug/L	-/-	ANR	ANR	ANR
2,4-Dimethylphenol	ug/L	-/-	ANR	ANR	ANR
2,4-Dinitrophenol	ug/L	-/-	ANR	ANR	ANR
2,4-Dinitrotoluene	ug/L	18/9.1	Comp	ND < 0.189	*
2,6-Dinitrotoluene	ug/L	-/-	ANR	ANR	ANR
2-Chloroethylvinylether	ug/L	-/-	ANR	ANR	ANR
2-Chloronaphthalene	ug/L	-/-	ANR	ANR	ANR
2-Chlorophenol	ug/L	-/-	ANR	ANR	ANR
2-Methyl-4,6-dinitrophenol	ug/L	-/-	ANR	ANR	ANR
2-Nitrophenol	ug/L	-/-	ANR	ANR	ANR
3,3'-Dichlorobenzidine	ug/L	-/-	ANR	ANR	ANR

OUTFALL 019 (Treatment System)

**THIRD QUARTER 2012 REPORTING SUMMARY
THE BOEING COMPANY
SANTA SUSANA FIELD LABORATORY
NPDES PERMIT CA0001309**

July 1 through September 30, 2012

ANALYTE	UNITS	Permit Limit Daily Max/Monthly Avg	09/05/2012-09/06/2012		
			SAMPLE TYPE	RESULT	VALIDATION QUALIFIER
4,4'-DDD	ug/L	-/-	ANR	ANR	ANR
4,4'-DDE	ug/L	-/-	ANR	ANR	ANR
4,4'-DDT	ug/L	-/-	ANR	ANR	ANR
4-Bromophenylphenylether	ug/L	-/-	ANR	ANR	ANR
4-Chloro-3-methylphenol	ug/L	-/-	ANR	ANR	ANR
4-Chlorophenylphenylether	ug/L	-/-	ANR	ANR	ANR
4-Nitrophenol	ug/L	-/-	ANR	ANR	ANR
Acenaphthene	ug/L	-/-	ANR	ANR	ANR
Acrolein	ug/L	-/-	ANR	ANR	ANR
Acrylonitrile	ug/L	-/-	ANR	ANR	ANR
Acute Toxicity	% SURVIVAL	70-100/-	ANR	ANR	ANR
Aldrin	ug/L	-/-	ANR	ANR	ANR
alpha-BHC	ug/L	0.03/0.01	Comp	ND < 0.0024	*
Anthracene	ug/L	-/-	ANR	ANR	ANR
Aroclor-1016	ug/L	-/-	ANR	ANR	ANR
Aroclor-1221	ug/L	-/-	ANR	ANR	ANR
Aroclor-1232	ug/L	-/-	ANR	ANR	ANR
Aroclor-1242	ug/L	-/-	ANR	ANR	ANR
Aroclor-1248	ug/L	-/-	ANR	ANR	ANR
Aroclor-1254	ug/L	-/-	ANR	ANR	ANR
Aroclor-1260	ug/L	-/-	ANR	ANR	ANR
Benzidine	ug/L	-/-	ANR	ANR	ANR
Benzo(a)anthracene	ug/L	-/-	ANR	ANR	ANR
Benzo(a)pyrene	ug/L	-/-	ANR	ANR	ANR
Benzo(b)fluoranthene	ug/L	-/-	ANR	ANR	ANR
Benzo(g,h,i)perylene	ug/L	-/-	ANR	ANR	ANR
Benzo(k)fluoranthene	ug/L	-/-	ANR	ANR	ANR
beta-BHC	ug/L	-/-	ANR	ANR	ANR
bis (2-Chloroethyl) ether	ug/L	-/-	ANR	ANR	ANR
bis (2-ethylhexyl) Phthalate	ug/L	4.0/-	Comp	ND < 1.60	*
bis(2-Chloroethoxy) methane	ug/L	-/-	ANR	ANR	ANR
bis(2-Chloroisopropyl) ether	ug/L	-/-	ANR	ANR	ANR
Bromodichloromethane	ug/L	-/-	ANR	ANR	ANR
Bromoform	ug/L	-/-	ANR	ANR	ANR
Bromomethane	ug/L	-/-	ANR	ANR	ANR
Butylbenzylphthalate	ug/L	-/-	ANR	ANR	ANR
Chlordane	ug/L	-/-	ANR	ANR	ANR
Chlorobenzene	ug/L	-/-	ANR	ANR	ANR
Chloroethane	ug/L	-/-	ANR	ANR	ANR
Chloromethane	ug/L	-/-	ANR	ANR	ANR
Chronic Toxicity	TUC	1.0/-	ANR	ANR	ANR
Chrysene	ug/L	-/-	ANR	ANR	ANR
cis-1,2-Dichloroethene	ug/L	-/-	Grab	ANR	
cis-1,3-Dichloropropene	ug/L	-/-			
Cyclohexane	ug/L	-/-			
delta-BHC	ug/L	-/-			
Dibenzo(a,h)anthracene	ug/L	-/-			

OUTFALL 019 (Treatment System)

**THIRD QUARTER 2012 REPORTING SUMMARY
THE BOEING COMPANY
SANTA SUSANA FIELD LABORATORY
NPDES PERMIT CA0001309**

July 1 through September 30, 2012

ANALYTE	UNITS	Permit Limit Daily Max/Monthly Avg	09/05/2012-09/06/2012		
			SAMPLE TYPE	RESULT	VALIDATION QUALIFIER
Dibromochloromethane	ug/L	-/-	ANR	ANR	ANR
Dieldrin	ug/L	-/-	ANR	ANR	ANR
Diethylphthalate	ug/L	-/-	ANR	ANR	ANR
Dimethylphthalate	ug/L	-/-	ANR	ANR	ANR
Di-n-butylphthalate	ug/L	-/-	ANR	ANR	ANR
Di-n-octylphthalate	ug/L	-/-	ANR	ANR	ANR
Endosulfan I	ug/L	-/-	ANR	ANR	ANR
Endosulfan II	ug/L	-/-	ANR	ANR	ANR
Endosulfan sulfate	ug/L	-/-	ANR	ANR	ANR
Endrin	ug/L	-/-	ANR	ANR	ANR
Endrin aldehyde	ug/L	-/-	ANR	ANR	ANR
Fluoranthene	ug/L	-/-	ANR	ANR	ANR
Fluorene	ug/L	-/-	ANR	ANR	ANR
Heptachlor	ug/L	-/-	ANR	ANR	ANR
Heptachlor epoxide	ug/L	-/-	ANR	ANR	ANR
Hexachlorobenzene	ug/L	-/-	ANR	ANR	ANR
Hexachlorobutadiene	ug/L	-/-	ANR	ANR	ANR
Hexachlorocyclopentadiene	ug/L	-/-	ANR	ANR	ANR
Hexachloroethane	ug/L	-/-	ANR	ANR	ANR
Indeno(1,2,3-cd)pyrene	ug/L	-/-	ANR	ANR	ANR
Isophorone	ug/L	-/-	ANR	ANR	ANR
Lindane (gamma-BHC)	ug/L	-/-	ANR	ANR	ANR
Methylene Chloride	ug/L	-/-	ANR	ANR	ANR
Monomethyl Hydrazine	ug/L	-/-	ANR	ANR	ANR
Naphthalene	ug/L	-/-	ANR	ANR	ANR
Nitrobenzene	ug/L	-/-	ANR	ANR	ANR
n-Nitrosodimethylamine	ug/L	16/8.1	Comp	ND < 0.0943	*
n-Nitroso-di-n-propylamine	ug/L	-/-	ANR	ANR	ANR
n-Nitrosodiphenylamine	ug/L	-/-	ANR	ANR	ANR
Pentachlorophenol	ug/L	16.5/8.2	Comp	ND < 0.377	*
Phenanthrene	ug/L	-/-	ANR	ANR	ANR
Phenol	ug/L	-/-	ANR	ANR	ANR
Pyrene	ug/L	-/-	ANR	ANR	ANR
Toxaphene	ug/L	-/-	ANR	ANR	ANR
trans-1,2-Dichloroethene	ug/L	-/-	ANR	ANR	ANR
trans-1,3-Dichloropropene	ug/L	-/-	ANR	ANR	ANR

Outfall 019 (Treatment System)

**THIRD QUARTER 2012 REPORTING SUMMARY
THE BOEING COMPANY
SANTA SUSANA FIELD LABORATORY
NPDES PERMIT CA0001309**

**Sample Type Composite
Sample Date July 2-3, 2012**

ANALYTE	LAB LOD (ug/L)	LAB RL (ug/L)	LAB RESULT (ug/L)
----------------	---------------------------	--------------------------	------------------------------

Outfall 019 (Treatment System)

**THIRD QUARTER 2012 REPORTING SUMMARY
THE BOEING COMPANY
SANTA SUSANA FIELD LABORATORY
NPDES PERMIT CA0001309**

**Sample Type Composite
Sample Date August 1-2, 2012**

ANALYTE	LAB LOD (ug/L)	LAB RL (ug/L)	LAB RESULT (ug/L)	VALIDATION QUALIFIER	1998 WHO TEF	BEF Great Lakes Water Quality Initiative	TCDD Equivalent (w/out DNQ Values) (ug/L)
1,2,3,4,6,7,8-HpCDD	2.70E-06	4.80E-05	ND	U (B)	0.01	0.05	ND
1,2,3,4,6,7,8-HpCDF	2.90E-06	4.80E-05	ND	U (B)	0.01	0.01	ND
1,2,3,4,7,8,9-HpCDF	3.80E-06	4.80E-05	ND	U	0.01	0.4	ND
1,2,3,4,7,8-HxCDD	3.70E-06	4.80E-05	ND	U	0.1	0.3	ND
1,2,3,4,7,8-HxCDF	6.00E-06	4.80E-05	ND	U	0.1	0.08	ND
1,2,3,6,7,8-HxCDD	3.70E-06	4.80E-05	ND	U	0.1	0.1	ND
1,2,3,6,7,8-HxCDF	5.80E-06	4.80E-05	ND	U	0.1	0.2	ND
1,2,3,7,8,9-HxCDD	3.00E-06	4.80E-05	ND	U	0.1	0.1	ND
1,2,3,7,8,9-HxCDF	6.60E-06	4.80E-05	ND	U	0.1	0.6	ND
1,2,3,7,8-PeCDD	7.10E-06	4.80E-05	ND	U	1	0.9	ND
1,2,3,7,8-PeCDF	9.40E-06	4.80E-05	ND	U	0.05	0.2	ND
2,3,4,6,7,8-HxCDF	5.20E-06	4.80E-05	ND	U	0.1	0.7	ND
2,3,4,7,8-PeCDF	9.90E-06	4.80E-05	ND	U	0.5	1.6	ND
2,3,7,8-TCDD	4.90E-06	9.60E-06	ND	U	1	1	ND
2,3,7,8-TCDF	9.30E-06	9.60E-06	ND	U	0.1	0.8	ND
OCDD	8.00E-06	9.60E-05	ND	U (B)	0.0001	0.01	ND
OCDF	5.20E-06	9.60E-05	ND	U (B)	0.0001	0.02	ND
TCDD TEQ w/out DNQ Values							ND

See attached notes for abbreviations, definitions, and other explanations for the data presented in this table.

OUTFALL 019 (Treatment System)

**THIRD QUARTER 2012 REPORTING SUMMARY
THE BOEING COMPANY
SANTA SUSANA FIELD LABORATORY
NPDES PERMIT CA0001309**

July 1 through September 30, 2012

ANALYTE	UNITS	Permit Limit Daily Max/Monthly Avg	07/02/2012-07/03/2012			08/01/2012-08/02/2012			09/05/2012-09/06/2012		
			Sample Type	Result	Concentration Result Validation Qualifier	Sample Type	Result	Concentration Result Validation Qualifier	Sample Type	Result	Concentration Result Validation Qualifier
Max Discharge for event	MGD	160	Meas	0.028757		Meas	0.022162		Meas	0.02902	
Ammonia as Nitrogen (N)	LBS/DAY	13,500/2615	Comp	0.07	J (DNQ)	Comp	ND	*	Comp	0.07	J,DX* (DNQ)
Biochemical Oxygen Demand (BOD 5 day)	LBS/DAY	40,032/26,700	Comp	0.98	--	Comp	ND	*	Comp	ND	*
Chloride	LBS/DAY	200,160/-	Comp	8.15	*	Comp	6.65	*	Comp	8.47	*
Surfactants (MBAS)	LBS/DAY	667/-	Comp	ND	*	Comp	ND	*	Comp	ND	*
Nitrate + Nitrite as Nitrogen (N)	LBS/DAY	10,700/-	Comp	ND	*	Comp	ND	*	Comp	ND	*
Nitrate as Nitrogen (N)	LBS/DAY	10,700/-	Comp	ND	*	Comp	ND	*	Comp	ND	*
Nitrite as Nitrogen (N)	LBS/DAY	1,334/-	Comp	ND	*	Comp	ND	*	Comp	ND	*
Oil & Grease	LBS/DAY	20,016/13,344	Grab	ND	*	Grab	ND	*	Grab	ND	*
Perchlorate	LBS/DAY	8.0/-	Comp	ND	U	Comp	ND	U	Comp	ND	U
Sulfate	LBS/DAY	400,320/-	Comp	35.97	*	Comp	29.57	*	Comp	38.72	*
Total Cyanide	LBS/DAY	11/5.7	Comp	ND	*	Comp	ND	*	Comp	ND	*
Total Dissolved Solids	LBS/DAY	1,270,000/-	Comp	124.71	*	Comp	97.96	*	Comp	140.36	*
Total Suspended Solids	LBS/DAY	60,048/20,016	Comp	ND	*	Comp	ND	*	Comp	ND	*
Cadmium	LBS/DAY	4.1/2.7	Comp	ND	*	Comp	ND	*	Comp	ND	*
Copper	LBS/DAY	19/9.5	Comp	ND	*	Comp	ND	*	Comp	ND	*
1,1-Dichloroethene	LBS/DA										
	Y	8.0/4.3	Grab	ND	*	Grab	ND	*	Grab	ND	*
Trichloroethene	LBS/DAY	6.7/-	Grab	ND	*	Grab	ND	*	Grab	ND	*
2,4,6-Trichlorophenol	LBS/DAY	17/8.7	Comp	ND	*	Comp	ND	*	Comp	ND	*
2,4-Dinitrotoluene	LBS/DAY	24/12	Comp	ND	*	Comp	ND	*	Comp	ND	*
alpha-BHC	LBS/DAY	0.04/0.013	Comp	ND	*	Comp	ND	*	Comp	ND	*
bis (2-ethylhexyl) Phthalate	LBS/DAY	5.3/-	Comp	ND	*	Comp	ND	*	Comp	ND	*
n-Nitrosodimethylamine	LBS/DAY	22/10.8	Comp	ND	BA* (BA)	Comp	ND	*	Comp	ND	*
Pentachlorophenol	LBS/DAY	22/10.9	Comp	ND	*	Comp	ND	*	Comp	ND	*
TCDD TEQ_NoDNQ	LBS/DAY	3.70E-08/1.9E-08	Comp	ND	--	Comp	ND	--	Comp	4.11E-14	--

ARROYO SIMI (Frontier Park Receiving Water)

**THIRD QUARTER 2012 REPORTING SUMMARY
THE BOEING COMPANY
SANTA SUSANA FIELD LABORATORY
NPDES PERMIT CA0001309**

July 1 through September 30, 2012

ANALYTE	UNITS	Permit Limit Daily Max/Monthly Avg	8/9/2012		
			SAMPLE TYPE	RESULT	VALIDATION QUALIFIER
pH (Field)	pH Units	6.5-8.5/-	Grab	7.4	*
Temperature	deg F	-/-	Grab	80	*
Hardness	mg/L	-/-	Grab	650	--
E. Coli	MPN/100 ml	235/-	ANR	ANR	ANR
Fecal Coliform	MPN/100 ml	400/-	ANR	ANR	ANR
Water Velocity	ft/sec	-/-	Meas	0.1	*
Chlorpyrifos	ug/L	0.02/-	Grab	ND < 0.080	U
4,4'-DDD	ug/L	0.0014/-	Grab	ND < 0.0038	*
4,4'-DDE	ug/L	0.001/-	Grab	ND < 0.0029	*
4,4'-DDT	ug/L	0.001/-	Grab	ND < 0.0038	*
Aroclor 1016	ug/L	0.0003/-	Grab	ND < 0.24	*
Aroclor 1221	ug/L	0.0003/-	Grab	ND < 0.24	*
Aroclor 1232	ug/L	0.0003/-	Grab	ND < 0.24	*
Aroclor 1242	ug/L	0.0003/-	Grab	ND < 0.24	*
Aroclor 1248	ug/L	0.0003/-	Grab	ND < 0.24	*
Aroclor 1254	ug/L	0.0003/-	Grab	ND < 0.24	*
Aroclor 1260	ug/L	0.0003/-	Grab	ND < 0.24	*
Chlordane	ug/L	0.001/-	Grab	ND < 0.076	*
Diazinon	ug/L	0.16/-	Grab	ND < 0.040	U
Dieldrin	ug/L	0.0002/-	Grab	ND < 0.0019	*
Toxaphene	ug/L	0.0003/-	Grab	ND < 0.24	*